



VERNON PUBLIC SCHOOLS
Facilities Department
375 Hartford Tpk
Vernon, CT 06066-0600
(860)870-3500 / Fax (860) 870-3505
Website: www.vernonpublicschools.org

Aquaponics Lab
FY24-003
Questions and Answers

Q: On Attachment B, please indicate what the Red, Blue and Purple utility lines represent.

A: Red is electrical, blue is domestic water, purple is storm water

Q: Please indicate if the utility box within the Blue line on Attachment B is live or simply needs to be demolished.

A: The “utility box” is an oil AST for the VOAG boiler. If it is in the way then it will need to be relocated.

Q: What level of quality is expected of the classroom space?

A: It needs to be an atmosphere that is inviting for students to learn and thrive.

Q: We understood from the walk through that a brick exterior may not be desirable. Please confirm this understanding.

A: This is correct, the district is looking for something that is inviting to students and guests. This is typically the area where guests and students walk by after parking their vehicles.

Q: What is the expected lifespan of this building? 5, 10, 20 or 30+ years?

A: 30+

Q: Can you please provide a list of specialty vendors you have, or plan to, engage?

A: Garland roof company, 3-way communications, CTC for digital controls and Pentair Aquatic ECO-Systems (fish farm 2)